





State Water Resources Control Board

Division of Drinking Water

February 5, 2016 Certified Mail/Return 7012 3460 0003 1113 0451

Verona Marina Launch & R.V. 3095 Dusty Lane Loomis, CA 95650

Attention: Greg Walker, Owner

Subject: Verona Marina Launch & R.V., Public Water System No. 5100159 - Compliance

Order for Exceedance of the Total Coliform Maximum Contaminant Level.

Enclosed is Compliance Order No. 21-16R-001 issued by the State Water Resources Control Board to Verona Marina Launch & R.V. for non-compliance with the maximum contaminant level for total coliform and for a failed well casing. Please read this order carefully. Continuous public notification, until the source is replaced, is required to inform consumers that the well water may not be safe to drink.

Per our phone conversation regarding this Order, please submit a written response indicating your acknowledgement of, and willingness to comply with the directives, therein.

Note that Section 116577 of the California Safe Drinking Water Act provides for the Division to be reimbursed by the public water system for costs incurred for preparing and issuing a compliance order. In accordance with Section 116577, the System will be billed for the preparation and issuance of this Order.

If you have any questions please call Paul Rowe at (530) 224-4866 or contact me directly at (530) 224-4861.

Reese B. Crenshaw, P.E. Valley District Engineer DRINKING WATER FIELD

OPERATIONS BRANCH

Enclosures

1 2 3 4 5 6 7 8	STATE OF CALIFORNIA STATE WATER RESOURCES CONTROL BOARD DIVISION OF DRINKING WATER		
9			
10	TO: Verona Marina Launch & R.V.		
11	Attn: Greg Walker, Owner		
12	3095 Dusty Lane		
13	Loomis, CA 95650		
14			
15			
16	COMPLIANCE ORDER FOR NONCOMPLIANCE WITH THE TOTAL COLIFORM		
17	MAXIMUM CONTAMINANT LEVEL		
18			
19	COMPLIANCE ORDER NO. 21-16R-001		
20			
21	Verona Marina Launch & R.V.		
22	System No. 5100159		
23	Issued: February 5, 2015		
24			
25	Section 116655 of Chapter 4 of Part 12 of Division 104 of the California Health and		
26	Safety Code (H&S Code) authorizes the issuance of a compliance order for failure to		
27	comply with a requirement of the California Safe Drinking Water Act or any		
28	regulation, standard, permit, or order issued thereunder.		
29			

1	The State Water Resources Control Board (hereinafter "Board"), acting by and
2	through its Division of Drinking Water (hereinafter "Division") and the Deputy Director
3	for the Division, hereby issues this compliance order (hereinafter "Order") pursuant
4	to Section 116655 of the California Health and Safety Code (hereinafter "CHSC") to
5	Verona Marina Launch & R.V. for violation of CHSC section 116655(a)(1) and title
6	22, California Code of Regulations (hereinafter "CCR"), Section 64431.
7	
8	APPLICABLE AUTHORITIES
9.	Section 116555 of the CHSC states in relevant part:
10	(a) Any person who owns a public water system shall ensure that the system
11	does all of the following:
12	(1) Complies with primary and secondary drinking water standards.
13	(3) Provides a reliable and adequate supply of pure, wholesome,
14	healthful, and potable water.
15	
16	Section 116655 of the CHSC states in relevant part:
17	(a) Whenever the department determines that any person has violated or is
18	violating this chapter, or any permit, regulation, or standard issued or
19	adopted pursuant to this chapter, the director may issue an order doing
20	any of the following:
21	(1) Directing compliance forthwith.
22	(2) Directing compliance in accordance with a time schedule set by the
23	department.
24	(3) Directing that appropriate preventive action be taken in the case of
25	a threatened violation.
26	

1	(b) An order issued pursuant to this section may include, but shall not be
2	limited to, any or all of the following requirements:
3	(1) That the existing plant, works, or system be repaired, altered, or
4	added to.
5	(2) That purification or treatment works be installed.
6	(3) That the source of the water supply be changed.
7	(4) That no additional service connection be made to the system.
8	(5) That the water supply, the plant, or the system be monitored.
9	(6) That a report on the condition and operation of the plant, works,
10	system, or water supply be submitted to the department.
11	
12	
13	Section 64426.1(b)(2), Title 22, of the CCR states in relevant part:
14	(b) A public water system is in violation of the total coliform maximum
15	contaminant level (MCL) when any of the following occurs:
16	(2) For a public water system which collects fewer than 40 samples
17	per month, more than one sample collected during any month is total
18	coliform-positive.
19	
20	
21	STATEMENT OF FACTS
22	The Verona Marina Launch & R.V. water system (hereinafter, "System") is classified
23	as a transient noncommunity water system located in Sutter County that supplies
24	water for domestic purposes to approximately 38 persons. The System operates a
25	groundwater well as its source of domestic water. On January 25, 2016, a routine
26	bacteriological sample collected from the distribution system indicated the presence
27	of total coliform bacteria. Consequently, four repeat samples were collected on

1	January 27, 2016, all of which indicated the presence of total coliform bacteria as
2	well. No sample discussed herein indicated the presence of E. coli bacteria.
3	
4	In response to the presence of total coliform in the System, the Division performed
5	an on-site inspection of the groundwater well and appurtenances on January 28,
6	2016. The following deficiencies were discovered concerning the well casing at the
7	time of the inspection: Extensive rusting, visible cracks and holes, and deformation
8	of the well casing were noted at the ground level. These deficiencies not only pose
9	as a potential source of introducing bacteriological contamination to the
10	groundwater, but also indicate that the overall structural integrity of the well casing
11	has been compromised.
12	
13	DETERMINATIONS
14	Based on the above Statement of Facts, The Division has determined that the
15	System is in violation of Section 64426.1(b)(2), Title 22, of the CCR and Section
16	116555(a)(3) of the CHSC, in that the System exceeded the total coliform MCL
17	during the month of January 2016, and that the water produced by the System's well
18	is not a reliable and adequate supply of pure, wholesome, healthful, and potable
19	water.
20	
21	DIRECTIVES
22	This compliance order includes the following directives for the System:
23	

26

24

25

1. Submit a written response by February 15, 2016, indicating a willingness

to comply with the directions of this order.

- 2. On or before August 1, 2016, the System must provide a new source of drinking water in order to continue operating as a water system for consumers. If the new source is a well, the System must obtain Division approval of a new well site prior to construction, and the well must be constructed to ensure that the top of the casing is above the 100 year flood zone or highest recorded flood level for the geographic location of the System per Section 8(C) of the California Well Standards (Bulletin 74-90) and Section 64560(c) of the CCR.
- Within no more than five (5) days after the new source is commissioned, the existing well must be properly destroyed per Section 64560.5 of the CCR.
- 4. Until such time that the System provides a new drinking water source, the System shall continue to post the attached boil water notice (Attachment 'A') in conspicuous locations throughout the area served by the System. The Water System shall submit a copy of the notice and certification (Attachment 'B') that it has been posted, to the Division no later than the tenth day of each month. The notification and certification shall be in the form and manner directed by the Division.

All submittals required by this Order shall be addressed to:

Reese B. Crenshaw, P.E.

Valley District Engineer

Drinking Water Field Operations

Division of Drinking Water

State Water Resources Control Board

364 Knollcrest Drive, Suite 101

.

Redding, CA 96002

(530) 224-4800

Nothing in this Order relieves the System of its obligation to meet the requirements of Health and Safety Code, Division 104, Part 12, Chapter 4 (California Safe Drinking Water Act), or any regulation, permit, standard or order issued or adopted thereunder.

The Division reserves the right to make such modifications to this Order, as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Order and shall be effective upon issuance.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to: issue citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Board; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with violates an order of the Board. The Board does not waive any further enforcement action by issuance of this citation.

1	PARTIES BOUND			
2	This Order shall apply to and be binding upon the System, its officers, directors,			
3	agents, employees, contractors, successors, and assignees.			
4				
5				
6	SEVERABILITY			
7	The directives of this Order are severable, and the System shall comply with each			
8	and every provision thereof notwithstanding the effectiveness of any other provision.			
9				
10				
11	12 101 11-1			
12	full 6 2/5/2016			
13	Richard L. Hinrichs, P.E., Chief Date			
14 15	Northern California Section State Water Resources Control Board			
16	Division of Drinking Water			
17				
18				
19				
20				
21				
22				
23				
24				
25				

BOIL WATER NOTICE

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

BOIL YOUR WATER BEFORE USING

Failure to follow this advisory could result in stomach or intestinal illness.

Due to a recent discovery of significant defects in the water supply well and the detection of total coliform bacteria in the drinking water supply, the State Water Resources Control Board, Division of Drinking Water in conjunction with the Verona Marina Launch & RV Water System are advising customers to use boiled tap water or bottled water for drinking and cooking purposes as a safety precaution.

DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST. Bring all water to a boil, **let it boil for one (1) minute**, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking and food preparation **until further notice**. Boiling kills bacteria and other organisms in the water.

We will inform you when tests show that water is safe to drink and you no longer need to boil your water. The problem will be resolved when a new well has been drilled and approved for use. The estimated time of completion is three months from now.

For more information call:

Water Utility contact: John Myers, Campground Manager, 916-927-8387. State Water Resources Control Board – Drinking Water Field Operations Branch- Valley District Office at 530-224-4800.

CERTIFICATION OF COMPLETION OF PUBLIC NOTIFICATION

This form, when completed and returned to the Division of Drinking Water (364 Knollcrest Drive, Suite 101, Redding, CA 96002 or fax to 530-224-4844), serves as certification that public notification to water users was completed as required by the California Water Quality and Monitoring Regulations. Completing public notification and providing the Division with certification is important. Failure to do so will result in additional hourly time charges to your water utility and may result in a formal enforcement action with monetary penalties.

Public water System Name	larina Launch & R.V.
Public Water System No. 5100159	·
Public notification for the month of, 2016 the following method:	6 bacteriological failure was performed by
Posting in conspicuous locations throughout the Please indicate the date(s) the notice was hand	
I hereby certify that the above information is factual.	
Pr	inted Name
Si	gnature
De	ate